



Mark Twain R-VIII School
37707 US HWY 160
Rueter, Mo. 65744
Phone 417-785-4323 Fax 417-785-9810

Joe Donley, Superintendent
Zack Yarger, Board President
Brad Hodges, Vice President
Abby Rinehart Secretary of Board
Chance Henson Member
Darren Tilley, Member
Suzanne Landry, Member
Paul Wyatt, Member

Lead Testing in School Drinking Water

In order to be compliant with the Missouri law known as the "Get the Lead out of School Drinking Water Act," the district conducted sampling and testing of all potential drinking water sources in the school. The results of the testing showed that all potential drinking sources were within the allowable range of less than 5 parts per billion (ppb).

Additional information and resources on the health effects of lead contamination are available here:

<http://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water#health>



Keystone Laboratories - Kansas City
 CERTIFICATE OF ANALYSIS
 3GK0072

Greenway Environmental Services

Zach Stuart
 190 Bobcat Ct
 Forsyth, MO 65653

Project Name: MO Schools Lead Testing-Mark Twain

Project / PO Number: Mark Twain / Mark Twain
 Received: 11/08/2023
 Reported: 11/22/2023

Analytical Testing Parameters

Client Sample ID:	Front Fountain	Collected By:	Stuart, Zach
Sample Matrix:	Drink Wtr	Collection Date:	11/03/2023 12:47
Lab Sample ID:	3GK0072-01		

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		11/21/23 0913	11/21/23 2204	RVV

Client Sample ID:	Back Fountain	Collected By:	Stuart, Zach
Sample Matrix:	Drink Wtr	Collection Date:	11/03/2023 12:50
Lab Sample ID:	3GK0072-02		

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		11/21/23 0913	11/21/23 2209	RVV

Client Sample ID:	Kitchen Sink	Collected By:	Stuart, Zach
Sample Matrix:	Drink Wtr	Collection Date:	11/03/2023 12:54
Lab Sample ID:	3GK0072-03		

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	2.6	0.4	ppb	2		11/21/23 0913	11/21/23 2213	RVV

Client Sample ID:	Kitchen Dish	Collected By:	Stuart, Zach
Sample Matrix:	Drink Wtr	Collection Date:	11/03/2023 12:54
Lab Sample ID:	3GK0072-04		

Analyses Performed by: Keystone Laboratories - Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		11/21/23 0913	11/21/23 2218	RVV

Definitions

RL: Reporting Limit